



- ① 10" CAST IRON VALVE BOX W/
CONCRETE COLLAR
- ② FINISH GRADE
- ③ CAST IRON ADJUSTABLE VALVE BOX
- ④ 2" SQUARE OPERATING UNIT
- ⑤ FLANGE x FLANGE GATE VALVE SEE
EQUIPMENT SCHEDULE
- ⑥ SCH. 80 FLANGE ADAPTER
- ⑦ MAIN WATER SUPPLY LINE
- ⑧ 6" MIN. GRAVEL
- ⑨ SUBGRADE COMPACTED TO 90%
- ⑩ DEPTH: 18" - 30"
- ⑪ SHRUBS - 2"; SOD - 1 1/2";
SEED - 1"

NOTES:

1. UNTREATED BASE COURSE: PROVIDE MATERIAL SPECIFIED IN APWA SECTION 02060. DO NOT USE GRAVEL OR SEWER ROCK. PLACE PER APWA SECTION 02322. COMPACT PER APWA SECTION 02324 TO A MODIFIED PROCTOR DENSITY OF 95% OR GREATER. MAXIMUM LIFT THICKNESS IS 8" BEFORE COMPACTION.
2. MAINTAIN 1/2" CLEARANCE BETWEEN SLEEVE SECTION AND RISER SECTION.

GATE VALVE

HYDE PARK CITY

113 E CENTER ST,
HYDE PARK, UT 84318
(435) 583-6507



GATE VALVE

IR-07

DATE: 02-25-2020