



PIPE DIA.	DIMENSION
3/4" - 1 1/2"	18"
2" - 3"	24"
4" - 6"	30"
8" - 10"	36"

NOTES:

1. UNIT MAY BE INSTALLED IN METAL OR CONCRETE ENCLOSURE, ENSURE THAT ENCLOSURE DRAINS FREELY.
2. PIPE LINE SHALL BE FLUSHED BEFORE INSTALLATION.
3. MOUNT UNIT IN UPRIGHT POSITION. INSTALL SUPPORTS PER MANUFACTURER RECOMMENDATION.
4. ALLOW CLEARANCE AROUND UNIT TO CONDUCT TESTING AND REPAIRS.
5. NEW INSTALLATION SHALL BE INSPECTED AND TESTED BY LICENSED BACKFLOW PREVENTION TESTER.
6. EXCEPT FOR MACHINED SURFACES, COAT ALL ITEMS EXPOSED TO ATMOSPHERE WITH EPOXY PAINT. COLOR TO BE SELECTED BY ENGINEER.
7. SHALL NOT BE INSTALLED IN A VAULT.

HYDE PARK CITY

113 EAST CENTER
HYDE PARK, UTAH 84318
TEL: (435) 563-6507



**REDUCED PRESSURE
BACKFLOW PREVENTION
(GROUND)**

CW-03

DATE: 02-09-21