



NOTES.

1. UNTREATED BASE COURSE PROVIDE MATERIAL SPECIFIED IN APWA SECTION 02060. DO NOT USE GRAVEL OF SEWER ROCK. PLACE PER APWA SECTION 02322. COMPACT PER APWA SECTION 02324 TO A MODIFIED PROCTOR DENSITY OF 95% OR GREATER. MAXIMUM LIFT THICKNESS IS 3" BEFORE COMPACTION.
2. MAINTAIN 1/2" CLEARANCE BETWEEN SLEEVE SECTION AND RISER SECTION.

GATE VALVE

HYDE PARK CITY

113 EAST CENTER
HYDE PARK, UTAH 84318
TEL: (435) 563-6507



GATE VALVE

IR-06

DATE: 02-10-21