

NOTES:

1. PROVIDE AGENCY APPROVED WYE OR TEE WITH APPROPRIATE DONUT. VERIFY WHETHER CONTRACTOR OR AGENCY IS TO INSTALL THE WYE.
2. TAPE WRAP PIPE AS REQUIRED BY SOIL CONDITIONS.
3. REMOVE CORE PLUG FROM SEWER MAIN. DO NOT BREAK INTO SEWER MAIN TO MAKE CONNECTION.
4. STAINLESS STEEL STRAPS REQUIRED.
5. PROVIDE AND PLACE PER APWA SECTION 33 05 20. COMPACT PER APWA SECTION 31 23 26 TO A MODIFIED PROCTOR DENSITY OF 95% OR GREATER. MAXIMUM LIFT THICKNESS IS 8 INCHES BEFORE COMPACTION.
6. IN HIGH WATER TABLE BOWL WAX REQUIRED
7. SEWER SADDLE PER AGENCY REQUIREMENTS.

