

All laterals are to be one continuous length of Type "K" one-inch copper tubing. No spliced joints will be allowed between the ball valve at the water main and the meter setter. The lateral is to be connected to the main with a Romac #202N service saddle and a Ford FB1100 ball valve and corp stop. The developer supplies and installs all materials from the city main to the meter, including the saddle, corp stop and ball valve, one-inch copper lateral, meter setter, shut-off valve, dual check valves, meter barrel, ring and lid.

