



- (A) 4" x 4" x 2" FLG TEE
- (B) 4" GATE VALVE
- (C) 2" FLG x PLAIN SPOOL
- (D) 4" COMPOUND METER
- (E) FLANGE COUPLING ADAPTER
- (F) FLG x FLG 90° ELBOW
- (G) FLG x FLG SPOOL

5 FT. FLOOR TO CEILING I.D.

- NOTES:**
1. THE CITY WILL DETERMINE WHETHER THE VAULT FLOOR SHALL BE CONCRETE OR GRAVEL.
 2. THE CITY WILL SPECIFY THE MAKE & MODEL OF THE METER TO BE PURCHASED & INSTALLED BY THE DEVELOPER.
 3. THE CITY WILL SPECIFY THE NUMBER, TYPE & LOCATION OF PIPE SUPPORTS BASED ON THE FLOOR MATERIAL. NO WOOD OR BRICK STANDS WILL BE ALLOWED.
 4. THE DEVELOPER SHALL SUPPLY & INSTALL A CITY-STANDARD GATE VALVE AT THE CONNECTION TO THE CITY'S WATER MAIN UPSTREAM OF THE VAULT.